

CITY OF NEW ROCHELLE				
DEPARTMENT OF PUBLIC WORKS - ENGINEERING				
EPA 02-2015 -3034 STEPHENSON BLVD OUTFALL & TRUNK LINE SAMPLING				
NY Water Quality Standards = 2,000 MPN/ 100ml Fecal & 10,000 MPN/ 100ml Total Coliform				
LOCATION	SAMPLE DATE	LAB SAMPLE RESULTS		Discharge Ratings
		FECAL PER 100 ml	COLIFORM PER 100 ml	Obvious/Suspect/ Potential/Unlikely
SDMH # 1 SW Corner Adams St & Jackson St (Bottle # 8059)	1/11/2017	17,000	17,000	Potential
SDMH # 1 IFO 26 Lincoln St House / Adams St (Bottle # 3279)	5/16/2017	240,000	240,000	Obvious
SDMH # 2 IFO 78 Monroe St House / Lincoln St (Bottle # 3000)	5/16/2017	45	35,000	Potential
SDMH # 3 The BLVD Island off Hamilton Ave (Bottle # 3314)	5/16/2017	350,000	540,000	Obvious
SDMH # 4 - 236 Hamilton Ave (Bottle # 3353)	6/22/2017	350,000	920,000	Obvious
SDMH # 5 - 142 Hamilton Ave (Bottle # 3690)	6/22/2017	13,000	46,000	Potential
SDMH # 6 - 125 Hamilton Ave (Bottle # 4175)	6/22/2017	45	270	Unlikely
D-2153 = SDMH # 7 - 40 Earle Place (Bottle # 3275)	7/19/2017	35,000	160,000	Potential
D-2156 = SDMH # 8 - 50 Hunter Ave (Bottle # 2906)	7/19/2017	24,000	54,000	Potential
D-2157 = SDMH # 9 - 56 Hunter Ave (Bottle # 3354)	7/19/2017	54,000	54,000	Potential
D-2158 = SDMH # 10 - 62 Hunter Ave (Bottle # 3219)	7/19/2017	54,000	240,000	Potential
D-2159 = SDMH # 11 - 66 Hunter Ave (Bottle # 4390)	7/19/2017	>1,600,000	>1,600,000	Obvious
SDMH # 16 - 256 Hamilton Ave (Bottle # 2363)	9/11/2017	>1600000	>1600000	Obvious
SDMH # 17 - Hamilton Ave Btwn 2 Pillars (Bottle # 3281)	9/13/2017	3,300	28,000	Unlikely
SDMH # 18 - Btwn 121 & 125 Hamilton Ave (Bottle # 4029)	9/13/2017	22,300	28,600	
SDMH # 19 - 61 Orchard Pl CB corner of Hamilton Ave & Orchard Pl (Bottle # 3377)	9/13/2017	920,000	>1600000	Obvious
SDMH # 20 - 178 Brookdale Ave & Lorenz Ave	9/13/2017	>1600000	>1600000	
SDMH # 22 - 121 Hamilton Ave (Bottle # 3188)	10/3/2017	<18	20	Unlikely
D-2415 = SDMH # 25 - 178 Brookdale Ave at Lorenz Ave	10/3/2017	22,000	22,000	Potential
D-2413 = SDMH # 26 - 66 Brookside Place (Bottle # 4450)	10/23/2017	46,000	70,000	Potential
D-3352 = SDMH # 27 - 19 Howard Pkwy (Bottle # 4463)	10/23/2017	170,000	170,000	Obvious
D-3352 = SDMH # 28 - 25 Howard Pkwy (Bottle # 4461)	10/23/2017	31,000	46,000	Potential
D-3346 = SDMH # 29 - 33 President St (Bottle # 4456)	10/23/2017	7,000	21,000	Potential
D-3344 = SDMH # 30 - Behind 34 President St - Iona College (Bottle # 4074)	10/23/2017	21,000	540,000	Obvious
SDMH # 36 -				
SDMH # 37 -				

COMMENTS
Notice of Violation
Wrong - Sample taken from sanitary line instead of storm line - Must re-sample for storm line in area
Wrong - Sample taken from sanitary line instead of storm line - Must re-sample for storm line in area
Retake - See SDMH # 22 on 10/03/17
Retake - See SDMH # 25 on 10/03/17
Changed Collection Bottle for Retake SDMH # 18
Changed Bottle Retake SDMH # 20